

**GREATER VISAKHAPATNAM MUNICIPAL CORPORATION**  
**FIRE PREVENTION WING**

**From:**  
The Commissioner,  
Greater Visakhapatnam  
Municipal Corporation,  
Visakhapatnam.

**To:**  
The District Educational Officer,  
Visakhapatnam District,  
Visakhapatnam

**Rc.No.00226/20/FPW/GVMC, Dt:27-10-2020**

**SUB:** Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing- Existing Building of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam – Renewal of Fire No Objection Certificate – Issued - Regarding.

- REF:**
1. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
  2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt: 13/09/2019.
  3. Fire No Objection Certificate for Occupancy vide Rc.No.6059/14/FPW/GVMC, Dt.01-05-2014.
  4. Renewal of Fire No Objection Certificate issued vide FN26101900020, Dt:18-11-2019 for Block-I.
  5. Renewal of Fire No Objection Certificate issued vide FN26101900039, Dt:18-11-2019 for Block-II.
  6. Application Dt:16-09-2020 of M/s.Apple I E.M. School, D.No.27-1-203/2, Srinagar, Gajuwaka, Visakhapatnam.
  7. Inspection Report of Station Fire Officer, GVMC Dt: 26-10-2020.

\*\*\*

It is to inform that vide reference 3<sup>rd</sup> cited, Fire No Objection Certificate for Occupancy was issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam and vide reference 4<sup>th</sup> & 5<sup>th</sup> cited, Renewal of Fire No Objection Certificates were issued to M/s.Apple I E.M. School D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam for Block-I & II separately.

- 2) Now, vide reference 6<sup>th</sup> cited, the management of M/s.Apple I E.M. School, D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam applied for issuance of Renewal of Fire No Objection Certificate for Block-I & II.
- 3) Vide reference 7<sup>th</sup> cited, the Station Fire Officer of Fire Prevention Wing, GVMC inspected the premises of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam on 23-10-2020 and submitted the following report.
- 4) The builder has constructed the Non Multi Storied Building (Block-I & II) with Ground + 03 Upper floors with a height of 13.00 Mtrs. for Educational Occupancy.
- 5) Particulars of The building:

a)	Address of the Premises	M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam
b)	Total Plot Area	1273.64 Sq. Mtrs (Block-I & II)
c)	Height of the Building	13.00 Mtrs
d)	No of blocks/ floors	02 Blocks / Ground + 03 Upper Floors
e)	Type of occupancy	Educational Building (School) – B1

**BLOCK-I** (D.No.27-1-203/2)

- 6) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Ground Floor	443.10	Educational (School)
2.	1 <sup>st</sup> Floor	508.38	Educational (School)
3.	2 <sup>nd</sup> Floor	483.82	Educational (School)
4.	3 <sup>rd</sup> Floor	483.82	Educational (School)
<b>Total</b>		<b>1919.12</b>	

- 7) The Builder has provided the following open places all round building.

Direction	Required as per G.O. No.168	Open space provided	Deficit
North (Front)	3.50 Mtrs	2.70 Mtrs	0.80 Mtrs
South	4.00 Mtrs	7.50 Mtrs	Nil
East	4.00 Mtrs	4.00 Mtrs	Nil
West	4.00 Mtrs	2.70 Mtrs	1.30 Mtrs

PRINCIPAL  
APPLE I E.M. SCHOOL  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-26 (AP)

For APPLE I E.M. SCHOOL

Authorised Signatory

:: 2 ::

8) Means Escape:

The Management has provided following means of escape

Sl. No.	Details of Staircase	Require Nos./ Mtrs.	Provided Nos./Mtrs.	From	To	Remarks / Deficit in Mtrs.
1	Internal	1 / 1.50	1 / 1.20	Ground	Terrace	0.30

9) The details of Occupant Load per unit Exit Width required and provided furnished as below.

Sl. No.	Floor	Build area (Sq.Mtrs.)	Occupancy type	No. of Occupants as per Management	Aggregate width of Staircases /Doors Required (Mtrs.)	Aggregate width of Staircases /Doors Provided (Mtrs.)	Deficit
1.	Ground Floor	443.10	Educational	100	1.00	Doors provided	Nil
2.	1 <sup>st</sup> Floor	508.38	Educational	100	1.00	1.20	Nil
3.	2 <sup>nd</sup> Floor	483.82	Educational	100	1.00	1.20	Nil
4.	3 <sup>rd</sup> Floor	483.82	Educational	100	1.00	1.20	Nil
<b>Total</b>		<b>1919.12</b>					

10) The Minimum Fire Safety Installations required &amp; provided by the Builder as per the Table -23 and other relevant clauses of part-4 of N.B.C of India 2005.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1	Fire Extinguishers as per IS 2190	19 No's	19 No's	Nil
2	Hose Reel	04 Nos.	04 Nos.	Nil
3	Down corner	01 No.	01 No.	Nil
4	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
5	Booster Pump	450 LPM	450 LPM	Nil

**BLOCK-II** (Dist No. 27-1-203/1)

11) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Ground Floor	277.96	Educational (School)
2.	1 <sup>st</sup> Floor	277.96	Educational (School)
3.	2 <sup>nd</sup> Floor	277.96	Educational (School)
4.	3 <sup>rd</sup> Floor	277.96	Educational (School)
<b>Total</b>		<b>1111.84</b>	

12) The Builder has provided the following open places all round building.

Direction	Required as per G.O. No.168	Open space provided	Deficit
North (Front)	3.50 Mtrs	2.70 Mtrs	0.80 Mtrs
South	4.00 Mtrs	7.00 Mtrs	Nil
East	4.00 Mtrs	2.00 Mtrs	2.00 Mtrs
West	4.00 Mtrs	4.00 Mtrs	Nil

13) Means Escape:

The Management has provided following means of escape

Sl. No.	Details of Staircase	Require Nos./ Mtrs.	Provided Nos./Mtrs.	From	To	Remarks / Deficit in Mtrs.
1	Internal	1 / 1.50	1 / 1.00	Ground	Terrace	0.50
2	External	1 / 1.50	1 / 1.00	Ground	Terrace	0.50
<b>Total</b>		<b>3.00</b>	<b>2.00</b>			<b>1.00</b>

14) The details of Occupant Load per unit Exit Width required and provided furnished as below.

Sl. No.	Floor	Build area (Sq.Mtrs.)	Occupancy type	No. of Occupants as per NBC	Aggregate width of Staircases /Doors Required (Mtrs.)	Aggregate width of Staircases /Doors Provided (Mtrs.)	Deficit
1.	Ground Floor	277.96	Educational (School)	69	0.69	Doors provided	Nil
2.	1 <sup>st</sup> Floor	277.96	Educational (School)	69	0.69	2.00	Nil
3.	2 <sup>nd</sup> Floor	277.96	Educational (School)	69	0.69	2.00	Nil
4.	3 <sup>rd</sup> Floor	277.96	Educational (School)	69	0.69	2.00	Nil
<b>Total</b>		<b>1162.05</b>					

*Self attested*  
**PRINCIPAL**  
**APPLE I E.M. SCHOOL**  
 Gajuwaka (P.O.)  
 Anapattanam-26 (AP)

For APPLE I E.M. SCHOOL

Contd.p.3

*[Signature]*  
 Authorised Signatory

15) The Minimum Fire Safety Installations required & provided by the Builder as per the Table -23 and other relevant clauses of part-4 of N.B.C of India 2005.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1	Fire Extinguishers as per IS 2190	12 No's	12 No's	Nil
2	Hose Reel	04 Nos.	04 Nos.	Nil
3	Down comer	01 No.	01 No.	Nil
4	Terrace Tank	10,000 Ltrs.	20,000 Ltrs.	Nil
5	Booster Pump	450 LPM	450 LPM	Nil

16) The management has remitted an amount of Rs.27,800/- vide challan No.2020-CH-09528, Dt.18-09-2020 and Rs.47,980/- vide challan No.2020-CH-09529, Dt.18-09-2020 towards fire precautionary fees and penal interest.

17) The Fire safety systems were tested by the Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

18) Therefore, **Renewal of Fire No Objection Certificate** is hereby issued to the Educational Building of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the firefighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

19) The **Renewal of Fire No Objection Certificate** issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam is **valid for 05 years from 18-11-2020 to 17-11-2025** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.

20) The issuing of Fire NOC will be without any prejudice to take action by GVMC against Unauthorized Construction, if any made.

(D.Niranjan Reddy)  
Regional Fire Officer  
Fire Prevention Wing

Greater Visakhapatnam Municipal Corporation,  
Visakhapatnam

**Copy to:**

- 1) The management, M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam T
- 2) The Chief City Planner, GVMC, Visakhapatnam.

*Self attested*

*[Signature]*  
PRINCIPAL  
APPLE I EM SCHOOL  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-26 (AP)

For APPLE I E.M. SCHOOL

*[Signature]*  
Authorised Signatory

Signed by Danda Niranjan  
Reddy

Date: 27-10-2020 18:13:50

Reason: Approved